

VOC Content Test Certificate

Friday, 07th September 2018

Supplier: CSR Lightweight Systems (376 Victoria Street, Wetherill Park, NSW, 2164)

Sample Description: CSR Gyprock One Finish Compound.

Date Tested: May 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	CSR Gyprock One Finish Compound
Sealers and prep coats: 65 grams per Litre as VOC content per material	8 grams per Litre as VOC content
<p><i>We hereby certify that CSR Gyprock One Finish Compound is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180869