

# Emission Test Certificate

Thursday 8<sup>th</sup> August 2024

<b>Manufacturer</b>	CSR Building Products Limited (376 Victoria Street, WETHERILL PARK, NSW 2164, Australia).
<b>Brand Name</b>	Glasroc X Sheathing Board.
<b>Date Tested</b>	August 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
<b>Test Method</b>	ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Emission Data (24 hrs):

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.2</b>	<b>Glasroc X Sheathing Board</b>
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.061 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission rate: 0.030 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr. Tuan Duong  
PhD, B.Eng. (Chemical)  
Senior Consultant

Issued date: 8/08/2024

Expiry date: 8/08/2029

P24060116