

Emission Test Certificate

Monday, October 12, 2015

Supplier: CSR Ltd (Trinity 3, 39 Delhi Road, North Ryde, NSW, 2113)

Sample Description: Gyprock Plus™ Plaster Board

Date Tested: October 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia Green Star Office Design IEQ-13</p>	<p align="center">GYPROCK PLUS™</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.025 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.030 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
PhD, B.E. Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV150949