

# Emission Test Certificate

Monday, 11<sup>th</sup> September 2017

Supplier: CSR Lightweight Systems (Triniti 3, 39 Delhi Road, North Ryde, NSW, 2113).

Sample Description: Gyprock Glasroc F

Date Tested: August 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<p><b>Green Building Council of Australia</b> <i>Green Star Interiors V1.1 - 12.1.2B</i> <i>Green Star Design &amp; As Built V1.1 - 13.1.2B</i></p>	<p><b>Gyprock Glasroc F</b></p>
<p>Total Volatile Organic Compound Emission Rate limit &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.026 mg/m<sup>2</sup>/hr</p>
<p>Total Formaldehyde Emission Rate limit: &lt;0.1 mg/m<sup>2</sup>/hr</p>	<p>Total Formaldehyde Emission Rate: 0.016 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BEng(Chemical Engineer)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV170823