

Emission Test Certificate

Wednesday, 12th December 2012

Supplier: CSR Lightweight Systems (Trinity 3, 39 Delhi Rd, North Ryde, 2113)

Sample Description: Gyprock FyrchekMR

Date Tested: November 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design IEQ-13	Gyprock FyrchekMR
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: <0.006 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Compound Emission Rate:<0.008 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV121005