

VOC Content Test Certificate

Tuesday December 2nd, 2008

Manufacturer: CSR Lightweight Systems (Level 1, 9 Help Street, Chatswood NSW 2067)

Sample Description: Gyprock™ Hardwall Plaster.

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">Gyprock™ Hardwall Plaster</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p><10 grams per Litre as VOC content per material</p>
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Gyprock™ Hardwall Plaster</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p><10 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-11