

# Emission Test Certificate

Thursday, March 31, 2016

Supplier: CSR Gyprock (376 Victoria Street, Wetherill Park, NSW, 2164)

Sample Description: Rigitone

Date Tested: March 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia Green Star Interiors V1.1 IEQ-13</b></p>	<p><b>Rigitone</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.027 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
PhD, B.E. Chem.  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV160324a