

Emission Test Certificate

Monday, 16th February 2015

Supplier: CSR Lightweight Systems (Locked Bag 26, 376 Victoria St, Wetherill Park, NSW 2164)

Sample Description: Gyprock™ Sensitive

Date Tested: January 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design IEQ-13	Gyprock™ Sensitive
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: <0.006 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Compound Emission Rate: <0.010 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150115