

# Emission Test Certificate

Wednesday, 12<sup>th</sup> December 2012

Supplier: CSR Lightweight Systems (Trinity 3, 39 Delhi Rd, North Ryde, 2113)

Sample Description: Gyprock Shaftliner

Date Tested: November 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Green Building Council of Australia Green Star Office Design IEQ-13</b>	<b>Gyprock Shaftliner</b>
Total Volatile Organic Compound Emission Rate limit <0.5mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: <0.003 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate limit <0.1mg/m <sup>2</sup> /hr	Formaldehyde Compound Emission Rate:<0.004 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

CV121005