

VOC Content Test Certificate

Tuesday December 2nd, 2008

Manufacturer: CSR Lightweight Systems (Level 1, 9 Help Street, Chatswood NSW 2067)

Sample Description: Gyprock™ Spray Plaster.

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Gyprock™ Spray Plaster
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<10 grams per Litre as VOC content per material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Gyprock™ Spray Plaster
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<10 grams per Litre as VOC content per material



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-11