

Emission Test Certificate

Friday, 18th July 2014

Supplier: CSR Lightweight Systems (Locked Bag 26, 376 Victoria St, Wetherill Park, NSW 2164)

Sample Description: Gyprock Standard Plasterboard

Date Tested: May 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design IEQ-13	Gyprock Standard Plasterboard
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.005 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Compound Emission Rate:0.008 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140521a