

VOC Content Test Certificate

Wednesday, 12th February 2014

Manufacturer: CSR Lightweight Systems (Trinity 3, 39 Delhi Road, North Ryde, NSW 2113)

Sample Description: Gyprock™ Ultra-AP All-Purpose Compound

Date Tested: January 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Gyprock™ Ultra-AP All-Purpose Compound</p>
<p align="center">Dry wall & panel adhesive</p> <p align="center">50 grams per Litre as VOC content per material</p>	<p align="center"><1 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AImm, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140111