

# VOC Content Test Certificate

Friday May 1<sup>st</sup>, 2012

Manufacturer: CSR Lightweight Systems (Trinity 3, 39 Delhi Rd, North Ryde, NSW 2113)

Sample Description: Ultra-Top Topping Compound

Date Tested: May 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ultra-Top Topping</b>  <b>Compound</b>
Dry wall & panel adhesive  50 grams per Litre as VOC content per material	<b>&lt;1 grams per Litre as VOC content</b> <b>per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120520