

# VOC Content Test Certificate

Monday, 25<sup>th</sup> March 2019

Supplier: CSR Building Products Ltd (Trinita 3, Level 5, 39 Deli Road, North Ryde, NSW, 2113).

Sample Description: Gyprock Wet Area Base Coat

Date Tested: March 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia Green Star Design &amp; As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</b></p>	<p align="center"><b>Gyprock Wet Area Base Coat</b></p>
<p align="center">General Purpose adhesives and Sealants: 50 grams per Litre as VOC content per material</p>	<p align="center"><b>4 gram per Litre as VOC content per material</b></p>
<p align="center"><i><b>We hereby certify Gyprock Wet Area Base Coat is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</b></i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV190363