

VOC Content Test Certificate

Monday, 17th October 2016

Manufacturer: CSR Limited (Trinity 3, 39 Delhi Road, North Ryde, NSW, 2113).

Sample Description: Rigitone Filler

Date Tested: March 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p>	<p>Rigitone Filler</p>
<p>General Purpose Adhesive and Sealants 50 grams per Litre as VOC content per material</p>	<p>13 gram per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV161031