

# VOC Content Test Certificate

Monday, 17<sup>th</sup> October 2016

Manufacturer: CSR Limited (Trinity 3, 39 Delhi Road, North Ryde, NSW, 2113).

Sample Description: Rigitone Primer

Date Tested: June 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Design &amp; As Built V1.1 13.1.1</b></p> <p><b>Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>RIGITONE PRIMER</b></p>
<p>General Purpose Adhesive and Sealants: 50 grams per Litre as VOC content per material</p>	<p><b>48 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV161031**