

# VOC Content Test Certificate

Monday, 2<sup>nd</sup> March 2015

Manufacturer: CSR Lightweight Systems (Locked Bag 26, 376 Victoria Street, Wetherill Park, NSW 2164)

Sample Description: CSR Gyprock Wet Area Acrylic Sealant

Date Tested: February 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>CSR Gyprock Wet Area Acrylic Sealant</b>
Architectural sealants*  250 grams per Litre as VOC content per material	<b>198 grams per Litre as VOC content per material</b>

\*Sealants used to enhance the fire and water-proofing properties are included.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV150115**