

VOC Content Test Certificate

Monday, 2nd March 2015

Manufacturer: CSR Lightweight Systems (Locked Bag 26, 376 Victoria Street, Wetherill Park, NSW 2164)

Sample Description: CSR Fireseal™ (Aus)

Date Tested: February 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	CSR Fireseal™ (Aus)
Architectural sealants* 250 grams per Litre as VOC content per material	170 grams per Litre as VOC content per material

*Sealants used to enhance the fire and water-proofing properties are included.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150115