

Emission Test Certificate

Thursday, March 31, 2016

Supplier: CSR Gyprock (376 Victoria Street, Wetherill Park, NSW, 2164)

Sample Description: Gyptone

Date Tested: March 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Interiors V1.1 IEQ-13</p>	<p>Gyptone</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.022 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
PhD, B.E. Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160324a