

VOC Content Test Certificate

Thursday, 16th January 2020

Supplier: CSR Building Products (376 Victoria Street, Wetherill Park, NSW 2164, Australia).

Sample Description: Gyprock Less Mess Multipurpose Compound.

Date Tested: 14 November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1224)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.2 13.1.1</p> <p>Green Star Interiors V1.2 12.1.1B</p>	<p>Gyprock Less Mess™</p> <p>Multi-Purpose Joint</p> <p>Compound</p>
<p>General purpose adhesives and sealants:</p> <p>50 grams per Litre as VOC content per material</p>	<p>47 gram per Litre as VOC content per material</p>
<p><i>We hereby certify Gyprock Less Mess Multipurpose Compound is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Dale Duncan
BSc (Hons)
Consultant

V1911028