

# VOC Content Test Certificate

Thursday, 16<sup>th</sup> January 2020

Supplier: CSR Building Products (376 Victoria Street, Wetherill Park, NSW 2164, Australia).

Sample Description: Gyprock Less Mess Topping Compound

Date Tested: 14 November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1224)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Design &amp; As Built V1.2 13.1.1</b></p> <p><b>Green Star Interiors V1.2 12.1.1B</b></p>	<p><b>Gyprock Less Mess™</b></p> <p><b>Topping Compound</b></p>
<p>General purpose adhesives and sealants:</p> <p>50 grams per Litre as VOC content per material</p>	<p><b>37 grams per Litre as VOC content</b></p> <p><b>per material</b></p>
<p><i>We hereby certify Gyprock Less Mess Topping Compound is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Dale Duncan  
BSc (Hons)  
Consultant

**V1911028**