

# Emission Test Certificate

Wednesday, 19<sup>th</sup> February 2020

Supplier: CSR Limited (376 Victoria Street, Wetherill Park, NSW, 2164, Australia)

Sample Description: CSR Shaft Liner MP Plasterboard Panel (Mould Resistant - 25mm thickness)

Date Tested: January 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 Hours):**

<p align="center"><b>Green Building Council of Australia Green Star Design &amp; As Built v1.3 - 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>CSR Shaft Liner MP Plasterboard Panel (Mould Resistant)</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.009 mg/m<sup>2</sup>/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: ≤0.1 mg/m<sup>2</sup>/hr</p>	<p align="center">Formaldehyde Emission Rate: 0.065 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dale Duncan  
BSc (Hons)  
Consultant



Dr. Tuan Duong  
BEng (Chemical)  
Senior Consultant

**V2001041**