

# VOC Content Test Certificate

Monday 01<sup>st</sup> February 2021

Supplier: CSR Building Products Limited (376 Victoria Street, Wetherill Park, NSW, 2164, Australia).

Sample Description: Gyprock Gold Topping Compound

Date Tested: December 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia Green Star Design &amp; As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</b></p>	<p align="center"><b>Gyprock Gold Topping Compound</b></p>
<p><b>General Purpose Adhesives and Sealants: 50 grams per Litre</b></p>	<p align="center"><b>8 grams per Litre as VOC content per material</b></p>
<p align="center"><i>We hereby certify that Gyprock Gold Topping Compound is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design &amp; As Built, and Green Star Interiors.</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

**V2012022**