

VOC Content Test Certificate

Thursday 19th March 2020

Supplier: CSR Building Products Limited (376 Victoria Street, Wetherill Park, NSW, 2164, Australia).

Sample Description: Gyprock Ultra-Base MR 60

Date Tested: March 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as Referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|--|---|
| <p align="center">Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p> | <p align="center">Gyprock Ultra-Base MR 60</p> |
| <p>General Purpose Adhesives and Sealants: 50 grams per Litre</p> | <p align="center">19 grams per Litre as VOC content per material</p> |
| <p align="center"><i>We hereby certify that Gyprock Ultra-Base MR 60 is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design & As Built, and Green Star Interiors.</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V2003049