

# VOC Content Test Certificate

Friday, 5<sup>th</sup> February 2016

Manufacturer: CSR Limited (Trinity 3, 39 Delhi Road, North Ryde, NWS, 2113).

Sample Description: Gyprock Easy-Base Pre-mixed Taping Compound

Date Tested: February 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Green Star Office Design V2 IEQ-13 Green Star Office Design V1.1 IEQ-11</b>	<b>Gyprock Easy-Base Pre-mixed</b>
Dry Wall and panel Adhesive 50 grams per Litre as VOC content per material	<b>8 gram per Litre as VOC content per material</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Gyprock Easy-Base Pre-mixed</b>
Dry Wall and panel Adhesive 50 grams per Litre as VOC content per material	<b>8 gram per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV160128**