

Emission Test Certificate

Wednesday 14th June 2023

Supplier CSR Building Products Ltd (Trinity 3, Level 5, 39 Delhi Road, North Ryde, NSW, 2113, Australia)

Product Name Gyprock Standard 13mm

Date Tested April 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

<p align="center">Green Building Council of Australia</p> <p align="center">Green Star Design & As Built V1.3 13.1.2B & 13.2</p> <p align="center">Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Gyprock Standard 13mm</p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.009 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.007 mg/m²/hr</p>
<p><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by CSR Building Products and these include Gyprock Supaceil™, Gyprock Plus™ 10mm, Gyprock Flexible 6.5mm and Gyprock Repair Panel.</i></p>	



Dr. Vyt Garnys
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr Tuan Duong
Ph.D., B.Eng. (Chemical)
Senior Consultant

Issued Date: 14/06/2023

Expired Date: 14/06/2028

P23030017