

Emission Test Certificate

Monday 21st August 2023

Supplier CSR Building Products Ltd (Trinity 3, Level 5, 39 Delhi Road, North Ryde, NSW, 2113, Australia)

Product Name Gyprock ECO8™ Complete

Date Tested April 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	Gyprock ECO8™ Complete
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.043 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.008 \text{ mg/m}^2/\text{hr}$
<p><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by CSR Building Products and these include Gyprock Fyrchek™, Gyprock Fyrchek™ MR, Gyprock Aquachek™, Gyprock HD, and Gyprock Soundchek™.</i></p>	



Dr. Vyt Garnys
 Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant



Dr Tuan Duong
 Ph.D., B.Eng. (Chemical)
 Senior Consultant

Issued Date: 13/06/2023

Expired Date: 14/06/2028

P23030017_Ver2